

TESTUTDRAG Kemikalier

Certificate Code:

Page 1 of 2

AR-24-TO-091869-01

Page Number:

FÖRE FILTER

	M502C	† Bromochloromethane	<5	µg/l
⇒	M502C	† Bromodichloromethane	12	µg/l
	M502C	† Bromomethane	<5	µg/l
	M502C	† Chlorobenzene	<1.0	µg/l
	M502C	† Chloroethane	<2.0	µg/l
⇒	M502C	† Chloroform (Trichloromethane)	20	µg/l

EFTER FILTER (Microspiral/kol)

	M502C	† Bromochloromethane	<5	µg/l
⇒	M502C	† Bromodichloromethane	<5	µg/l
	M502C	† Bromomethane	<5	µg/l
	M502C	† Chlorobenzene	<1.0	µg/l
	M502C	† Chloroethane	<2.0	µg/l
⇒	M502C	† Chloroform (Trichloromethane)	<1.0	µg/l